



Send To: C0177010

Mr. Zhou
Taizhou Tonhe Flow Control Equipment Co., Ltd.
Xincheng Road 1012
Huangyan Taizhou, Zhejiang 318020
China

Facility: C0177011

Taizhou Tonhe Flow Control Equipment Co., Ltd.
Xincheng Road 1012
Huangyan Taizhou, Zhejiang 318020
China

| Result | PASS | Report Date | 28-FEB-2014 |
|-------------------|--|-------------|-------------|
| Customer Name | Taizhou Tonhe Flow Control Equipment Co., Ltd. | | |
| Tested To | NSF/ANSI 61 | | |
| Description | 2" Electric Control Valve A100 series motorized valve T50-S2-C | | |
| Trade Designation | A100 series motorized valve T50-S2-C | | |
| Test Type | Qualification | | |
| Job Number | J-00133954 | | |
| Project Number | 9170340 (CL01, TE01) | | |
| Project Manager | YingJue (Joyce) Guo | | |

Thank you for having your product tested by NSF International.

Please contact your Project Manager if you have any questions or concerns pertaining to this report.

Report Authorization 
Amanda Phelka - Director, Toxicology Services

Date 28-FEB-2014



General Information

Standard: NSF/ANSI 61

Custom Sample Details: Component: Valve

DCC Number: PM14853

Lot Number: DN-50

Physical Description of Sample: 2" Electric Control Valve

Trade Designation/Model Number: A100 series motorized valve T50-S2-C

Sample Id: **S-0001012880**
 Description: Sample exposed at 23C and pH 8
 Sampled Date: 02/21/2014
 Received Date: 01/29/2014

Normalization Information:

| | | | | | | | |
|-----------------------------|-------------|----------------------|---------|----------------------|----------|--------------------|----------|
| Date exposure completed: | 21-FEB-2014 | Calculated N1: | 1.00 | Field Exposure Time: | 12 hours | Lab Exposure Time: | 16 hours |
| Field Number of Units: | 1 units | Lab Number of Units: | 2 units | Calculated N2: | 1.00 | Calculated N4: | 1.000 |
| Field Static Volume: | 1 L | Lab Static Volume: | 2.00 L | Constant N2: | 1 | Misc. Factor: | 0.33 |
| | | | | Calculated NFm: | 1.00 | | |
| Compound Reference Key: TAC | | | | | | | |

| Testing Parameter | Sample | Control | Result | Normalized Result | Units |
|---|--------|----------|--------|-------------------|-------|
| Chemistry Lab | | | | | |
| * Standard 61 Additives LAB SUM TEST Code | | | | | |
| External Note: 1 unit = 1 valve. Total of 2 units exposed in product. | | | | | |
| BASE/NEUTRAL/ACID EPA METHOD 625 Scan for Tentatively Identified Compound | | | | | |
| No Compounds Detected | ND(4) | Complete | ND(4) | ND(1) | ug/L |
| Scan Control Complete | TRUE | | | | |
| Semivolatile Compounds, Base/Neutral/Acid Target 625, Data Workup | | | | | |
| Pyridine | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Nitrosodimethylamine (N-) | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| N-Nitrosomethylethylamine | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 5-Methyl-2-hexanone (MIAK) | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 1-Methoxy-2-propanol acetate | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 2-Heptanone | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Cyclohexanone | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Nitrosodiethylamine (N-) | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Isobutylisobutyrate | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Aniline | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Phenol | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Di(chloroethyl) ether | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 2-Chlorophenol | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 2,3-Benzofuran | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 1,3-Dichlorobenzene | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 1,4-Dichlorobenzene | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 3-Cyclohexene-1-carbonitrile | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 2-Ethylhexanol | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Benzyl alcohol | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |



Sample Id: S-0001012880

| Testing Parameter | Sample | Control | Result | Normalized Result | Units |
|---|--------|---------|--------|-------------------|-------|
| Chemistry Lab (Continued) | | | | | |
| 1,2-Dichlorobenzene | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| bis(2-Chloroisopropyl)ether | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 2-Methylphenol (o-Cresol) | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| N-Methylaniline | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Acetophenone | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| N-Nitrosodi-n-propylamine | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| N-Nitrosopyrrolidine | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 4-Methylphenol (p-Cresol) | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Hexachloroethane | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 2-Phenyl-2-propanol | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| N-Nitrosomorpholine | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Nitrobenzene | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 2,6-Dimethylphenol | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| N-Vinylpyrrolidinone | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| N-Nitrosopiperidine | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Triethylphosphate | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Isophorone | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 2-Nitrophenol | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 2,4-Dimethylphenol | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| bis(2-Chloroethoxy)methane | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 2,4-Dichlorophenol | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Trichlorobenzene (1,2,4-) | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Naphthalene | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 4-Chloroaniline | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 1,1,3,3,-Tetramethyl-2-thiourea | ND(4) | ND(4) | ND(4) | ND(1) | ug/L |
| Hexachlorobutadiene | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Benzothiazole | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| N-Nitrosodi-n-butylamine | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 4-Chloro-3-methylphenol | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| p-tert-Butylphenol | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 2-Ethylhexyl glycidyl ether | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 2,6-Di-t-butyl-4-methylphenol(BHT) | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Methylnaphthalene, 2- | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Benzyl alcohol, a,a-dimethyl-p-isopropyl- | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Cyclododecane | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 2,4,5-Trichlorophenol | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 2,4,6-trichlorophenol | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 1(3H)-Isobenzofuranone | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 2-Chloronaphthalene | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 2-Nitroaniline | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 1,1'-(1,3-Phenylene)bis ethanone | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 2,6-Di-tert-butylphenol | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Dimethylphthalate | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 1,1'-(1,4-Phenylene)bis ethanone | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |



Sample Id: S-0001012880

| Testing Parameter | Sample | Control | Result | Normalized Result | Units |
|---|--------|---------|--------|-------------------|-------|
| Chemistry Lab (Continued) | | | | | |
| Acenaphthylene | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Benzenedimethanol, a,a,a',a'-tetramethyl-1,3- | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 2,6-Dinitrotoluene | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 2,4-Dinitrotoluene | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Benzenedimethanol, a,a,a',a'-Tetramethyl-1,4- | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 2,4-Di-tert-butylphenol | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Dimethyl terephthalate | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Acenaphthene | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Dibenzofuran | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Ethyl-4-ethoxybenzoate | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 4-Nitrophenol | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Cyclododecanone | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Diethyl Phthalate | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| p-tert-Octylphenol | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Fluorene | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 4-Chlorophenylphenylether | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 3-Nitroaniline | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 4-Nitroaniline | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Nitrosodiphenylamine (N-) | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Azobenzene | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 4-Bromophenylphenylether | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Hexachlorobenzene | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Pentachlorophenol | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Phenanthrene | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Anthracene | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Diisobutyl phthalate | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Dibutyl phthalate | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Hydroxymethylphenylbenzotriazole | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Fluoranthene | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Pyrene | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Butyl benzyl phthalate | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Di(2-ethylhexyl)adipate | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| 3,3-Dichlorobenzidine | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Benzo(a)anthracene | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Di(2-ethylhexyl)phthalate | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Chrysene | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Di-n-octylphthalate | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Benzo(b)fluoranthene | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Benzo(k)fluoranthene | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Benzo(a)Pyrene (PAH) | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Dibenzo(a,h)anthracene | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Indeno(1,2,3-cd)pyrene | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| Benzo(g,h,i)perylene | ND(2) | ND(2) | ND(2) | ND(0.5) | ug/L |
| * Perfluorooctanoic acid by LCMS/ES- | | | | | |



Sample Id: S-0001012880

| Testing Parameter | Sample | Control | Result | Normalized Result | Units |
|---|---------|---------|---------|-------------------|-------|
| Chemistry Lab (Continued) | | | | | |
| Perfluorooctanoic acid by LCMS/ES-" | ND(1) | ND(1) | ND(1) | ND(0.2) | ug/L |
| Volatile Organic Compounds (Ref: EPA 524.2) | | | | | |
| Dichlorodifluoromethane | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| Chloromethane | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| Vinyl Chloride | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| Bromomethane | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| Chloroethane | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| Trichlorofluoromethane | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| Trichlorotrifluoroethane | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| Methylene Chloride | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| 1,1-Dichloroethylene | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| trans-1,2-Dichloroethylene | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| 1,1-Dichloroethane | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| 2,2-Dichloropropane | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| cis-1,2-Dichloroethylene | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| Chloroform | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| Bromochloromethane | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| 1,1,1-Trichloroethane | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| 1,1-Dichloropropene | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| Carbon Tetrachloride | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| 1,2-Dichloroethane | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| Trichloroethylene | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| 1,2-Dichloropropane | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| Bromodichloromethane | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| Dibromomethane | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| cis-1,3-Dichloropropene | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| trans-1,3-Dichloropropene | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| 1,1,2-Trichloroethane | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| 1,3-Dichloropropane | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| Tetrachloroethylene | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| Chlorodibromomethane | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| Chlorobenzene | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| 1,1,1,2-Tetrachloroethane | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| Bromoform | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| 1,1,2,2-Tetrachloroethane | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| 1,2,3-Trichloropropane | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| 1,3-Dichlorobenzene | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| 1,4-Dichlorobenzene | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| 1,2-Dichlorobenzene | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| Carbon Disulfide | ND(1) | ND(1) | ND(1) | ND(0.2) | ug/L |
| Methyl-tert-Butyl Ether (MTBE) | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| tert-Butyl ethyl ether | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| Methyl Ethyl Ketone | ND(5) | ND(5) | ND(5) | ND(1) | ug/L |
| Methyl Isobutyl Ketone | ND(5) | ND(5) | ND(5) | ND(1) | ug/L |



Sample Id: **S-0001012880**

| Testing Parameter | Sample | Control | Result | Normalized Result | Units |
|------------------------------------|---------|---------|---------|-------------------|-------|
| Chemistry Lab (Continued) | | | | | |
| Toluene | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| Ethyl Benzene | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| m+p-Xylenes | ND(1) | ND(1) | ND(1) | ND(0.2) | ug/L |
| o-Xylene | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| Styrene | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| Isopropylbenzene (Cumene) | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| n-Propylbenzene | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| Bromobenzene | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| 2-Chlorotoluene | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| 4-Chlorotoluene | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| 1,3,5-Trimethylbenzene | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| tert-Butylbenzene | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| 1,2,4-Trimethylbenzene | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| sec-Butylbenzene | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| p-Isopropyltoluene (Cymene) | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| 1,2,3-Trimethylbenzene | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| n-Butylbenzene | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| 1,2,4-Trichlorobenzene | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| Hexachlorobutadiene | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| 1,2,3-Trichlorobenzene | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| Naphthalene | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| Benzene | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| Total Trihalomethanes | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |
| Total Xylenes | ND(0.5) | ND(0.5) | ND(0.5) | ND(0.1) | ug/L |

Sample Id: **S-0001012881**
 Description: 2" Electric Control Valve
 Sampled Date: 01/29/2014
 Received Date: 01/29/2014

| Testing Parameter | Sample | Control | Result | Normalized Result | Units |
|------------------------------------|--------|---------|--------|-------------------|-------|
| Chemistry Lab | | | | | |
| Material Screening for Lead by XRF | | | | | |
| Lead content verification | Pass | | | | |



Testing Laboratories:

All work performed at: —————▶

| | |
|------------------------------|---|
| Id ----- NSF_AA | Address ----- NSF International 789 N. Dixboro Road Ann Arbor MI 48105 |
|------------------------------|---|

References to Testing Procedures:

| NSF Reference ----- | Parameter / Test Description ----- |
|-------------------------------|---|
| C0513 | Material Screening for Lead by XRF |
| C1031 | * Standard 61 Additives LAB SUM TEST Code |
| C2023 | BASE/NEUTRAL/ACID EPA METHOD 625 Scan for Tentatively Identified Compounds (TICs) |
| C2024 | Semivolatile Compounds, Base/Neutral/Acid Target 625, Data Workup |
| C4656 | * Perfluorooctanoic acid by LCMS/ES- |
| C4662 | Volatile Organic Compounds (Ref: EPA 524.2) |

Test descriptions preceded by an asterisk "*" indicate that testing has been performed per NSF International requirements but is not within its scope of accreditation.